

# ELECTRICAL INSTALLATION CONDITION REPORT

1619 - Master



<b>A. Details of the Client/Person Ordering the Report</b> Client: <b>J Clawson</b> Address: <b>8 Woodlands View Douglas Isle Of Man IM2 2BT</b>		<b>B. Reason for Producing this Report</b> Purpose of this report: <b>To determine condition of electrical installation</b> Date(s) on which inspection and testing was carried out: <b>12/03/2018</b>	
<b>C. Details of the Installation which is the Subject of this Report</b> Installation: <b>Manxonia House</b> Occupier: <b>Port St Mary Commissioners</b> Address: <b>Manxonia House Manxonia House Bay View Road Port St Mary</b> Record of Installation available: <b>N/A</b> Records held By: <b>N/A</b>		Description of premises: Domestic <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Industrial <input type="checkbox"/> Other: <b>N/A</b> Estimated age of wiring system: <b>20+</b> yrs Evidence of alterations or additions: <b>N/A</b> If yes estimated Age: <b>N/A</b> yrs Date of previous inspection: <b>Not Known</b>	
<b>D. Extent and Limitations Inspection and Testing</b> Extent of Electrical Installation covered by this report: <b>All circuits</b> Operational Limitations including the reasons (See page No <b>N/A</b> ) <b>None</b>		Agreed limitations including the reasons (See regulation 634.2) <b>None</b> Agreed with name <b>N/A</b>	
This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS7671:2008 (IET Wiring Regulations) as amended to July 2015. It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.			
<b>E. Summary of the Condition of the Installation</b> Installation requires extensive modernisation. Electrical components and distribution boards shown signs of age and require -See Additional Page- Overall assessment of the installation: <b>Unsatisfactory</b> *An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified		General condition of the installations (In terms of electrical safety):	
<b>F. Recommendations</b> Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code F1). Observation classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken I recommend that the installation is further inspected and tested by <b>21/03/2023</b>			
<b>G. Declaration</b> I, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by My signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.		Trading Title and address: <b>Raven Electrical Services Limited, 1A Lake Road, Douglas, Isle Of Man, IM1 5AF</b> ECA Registration Number: <b>1644330</b>	
Inspected and tested by: Name: <b>Lee Corlett</b> Position: <b>Electrician</b> Signature:  Date: <b>21/03/2018</b>		Report authorised for issue by: Name: <b>David Benjamin Jones</b> Position: <b>Director</b> Signature:  Date: <b>21/03/2018</b>	
<b>H. Schedule(s)</b> The attached schedule(s) are part of this document and this report is valid only when they are attached to it. 0 Schedule(s) of inspection and 5 Schedule(s) of test results are attached			

I. Supply Characteristics and Earthing Arrangements				Nature of Supply Parameters		Supply protective device				
Earthing Arrangements		Number and Type of Live Conductors								
TN-S	<input type="checkbox"/> N/A	a.c.	<input checked="" type="checkbox"/>	d.c.	<input type="checkbox"/> N/A	Nominal Voltage $U^{(1)}$	400	V	BS(EN)	
TN-C-S	<input type="checkbox"/> N/A	1-Phase (2 wire)	<input type="checkbox"/> N/A	1-Phase (3 wire)	<input type="checkbox"/> N/A	Nominal Voltage $U_0^{(1)}$	230	V	1361 Fuse HBC	
TN-C	<input type="checkbox"/> N/A	2-Phase (3 wire)	<input type="checkbox"/> N/A	2 Wire	<input type="checkbox"/> N/A	Nominal frequency $f^{(1)}$	50	Hz	Type	
TT	<input checked="" type="checkbox"/>	3-Phase (3 wire)	<input type="checkbox"/> N/A	3 Wire	<input type="checkbox"/> N/A	Prospective fault current $I_{pf}^{(2)}$	1.74	kA	2	
IT	<input type="checkbox"/> N/A	Other	<input type="checkbox"/> N/A		Other	External loop impedance $Z_e^{(2)}$	50	$\Omega$	Nominal current rating	100 A
Confirmation of supply polarity				<input checked="" type="checkbox"/>	Number of supplies		1		Short circuit capacity	33 kA
					(Note: (1) by enquiry, (2) by enquiry or by measurement)					

J. Particulars of Installation Referred to in the Report			
Means of earthing		Details of installation Earth Electrode (where applicable)	
Distributor's facility	<input type="checkbox"/> N/A	Type (e.g. rod(s), tape etc.)	Earth Rod
Installation earth electrode	<input checked="" type="checkbox"/>	Resistance to Earth	50 $\Omega$
		Location	Below MUA cutout
		Method of measurement	Test Method 2 (Loop Tester)

Main Protective Conductors		Tick boxes and enter details as applicable	
Earthing Conductor	Material: Copper	csa: 6	mm <sup>2</sup>
Main protective bonding conductors	Material: Copper	csa: 6	mm <sup>2</sup>
Bonding of Incoming Service		Maximum Demand (Load)	
Water installation pipes	<input type="checkbox"/> N/A	Gas installation pipes	<input type="checkbox"/> N/A
Oil installation pipes	<input type="checkbox"/> N/A	Structural Steel	<input type="checkbox"/> N/A
Other incoming service(s)		Lightning protection	
<input type="checkbox"/> N/A <input type="checkbox"/> N/A		<input type="checkbox"/> N/A	
Please State		33 kVA	
		Protective measure(s) against electric shock	
		ADS	

Main Switch / Switch-Fuse / Circuit-Breaker / RCD			
Location	<input type="checkbox"/> N/A	Current rating	80 A
Type BS(EN)	5419 Isolator	Fuse/Device rating or setting	<input type="checkbox"/> N/A A
Supply Conductors material	Copper	Voltage rating	230 V
Supply Conductors csa	16	if RCD main switch	
		Rated residual operation current, I <sub>Δn</sub>	<input type="checkbox"/> N/A mA
		Rated time delay	<input type="checkbox"/> N/A ms
		RCD Operating time at, I <sub>Δn</sub>	<input type="checkbox"/> N/A ms

K. Observations		
Referring to the attached schedule(s) of Inspection and Test Results, and subject to the limitations specified at the Extent and Limitations of the Inspection and testing section		
No remedial action is required	<input type="checkbox"/> N/A	The following observations are made <input checked="" type="checkbox"/>
Item No	Observations	Code
1	3 EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54) 3.2 Presence and condition of earth electrode connection where applicable (542.1.2.3)	C3
2	3 EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54) 3.3 Provision of earthing/bonding labels at all appropriate locations (514.13.1)	C3
3	3 EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54) 3.4 Confirmation of earthing conductor size --Observations continue on continuation sheet(s)--	C3
One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.		
C1 - Danger present. Risk of injury. Immediate remedial action required	<input type="checkbox"/> 0	
C2 - Potentially dangerous - urgent remedial action required	<input type="checkbox"/> 2	
C3 - Improvement recommended	<input type="checkbox"/> 7	
FI - Further investigation required without delay	<input type="checkbox"/> 0	

**CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY**

1619 - Master

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome	Comments		
<b>1.0</b>	<b>DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT</b>													
1.1	Condition of service cable										✓	No		
1.2	Condition of Service head										✓	No		
1.3	Condition of distributor's earthing arrangement										N/A	No		
1.4	Condition of meter tails - Distributor/Consumer										✓	No		
1.5	Condition of metering equipment										✓	No		
1.6	Condition of Isolator (where present)										✓	No		
<b>2.0</b>	<b>PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES</b>										N/A	No		
<b>3.0</b>	<b>EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)</b>													
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)										N/A	No		
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)										C3 (see section K)	No		
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)										C3 (see section K)	No		
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)										C3 (see section K)	No		
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)										✓	No		
3.6	Confirmation of main protective bonding conductor sizes (544.1)										✓	No		
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)										✓	No		
3.8	Accessibility and condition of other protective bonding connections (543.3.2)										✓	No		
<b>4.0</b>	<b>CONSUMER UNIT (S) / DISTRIBUTION BOARD(S)</b>													
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)										✓	No		
4.2	Security of fixing (134.1.1)										✓	No		
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)										✓	No		
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)										C3 (see section K)	No		
4.5	Enclosure not damaged/deteriorated so as to impair safety (Regulation 621.2 (iii))										✓	No		
4.6	Presence of linked main switch (as required by 537.1.4)										✓	No		
4.7	Operation of main switch (functional check) (612.13.2)										✓	No		
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)										✓	No		
4.9	Correct identification of circuit details and protective devices (514.8.1;514.9.1)										✓	No		
4.10	Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)										C3 (see section K)	No		
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)										N/A	No		
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)										N/A	No		
4.13	Presence of other required labelling (please specify)(Section 514)										N/A	No		
4.14	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(421.1.3)										✓	No		
4.15	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.2)										✓	No		
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.11)										C3 (see section K)	No		
4.17	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1) )										N/A	No		
4.18	RCD(s) provided for fault protection – includes RCBOs(411.4.9; 411.5.2; 531.2)										C2 (see section K)	No		
4.19	RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1)										C2 (see section K)	No		
4.20	Confirmation of indication that SPD is functional (534.2.8)										N/A	No		
4.21	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure (526.1)										✓	No		
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)										N/A	No		
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)										N/A	No		
<b>5.0</b>	<b>FINAL CIRCUITS</b>													
5.1	Identification of conductors (514.3.1)										✓	No		
5.2	Cables correctly supported throughout their run (522.8.5)										LIM	No		
5.3	Condition of insulation of live parts (416.1)										✓	No		



**CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED**

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome	Comments		
<b>5.0</b>	<b>FINAL CIRCUITS (Continued)</b>													
5.4.0	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)										N/A	No		
5.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)										N/A	No		
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										✓	No		
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)										✓	No		
5.7	Adequacy of protective devices; type and rated current for fault protection (411.3)										✓	No		
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)										✓	No		
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)										✓	No		
5.10	Concealed cables installed in prescribed zones (see section D. Extent and limitations) (522.6.202)										LIM	No		
5.11	Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204)										✓	No		
5.12.0	Provision of additional protection by RCD not exceeding 30mA													
5.12.1	For all socket-outlets of rating 20 A or less, unless an exception is permitted (411.3.3)										✓	No		
5.12.2	For supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										✓	No		
5.12.3	For cables concealed in walls at a depth of less than 50mm (522.6.202; 522.6.203)										✓	No		
5.12.4	For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)										N/A	No		
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										N/A	No		
5.14	Band II Cables segregated / separated from Band I cables (528.1)										LIM	No		
5.15	Cables segregated / separated from communications cabling (528.2)										LIM	No		
5.16	Cables segregated / separated from non-electrical services (528.3)										LIM	No		
5.17.0	Termination of cables at enclosures – indicate extent of sampling in Section D of the report (Section 526)													
5.17.1	Connections soundly made and under no undue strain (526.6)										✓	No		
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)										✓	No		
5.17.3	Connections of live conductors adequately enclosed (526.5)										✓	No		
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc...) (522.8.5)										✓	No		
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))										C3 (see section K)	No		
5.19	Suitability of accessories for external influences (512.2)										✓	No		
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)										✓	No		
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.2)										✓	No		
<b>6.0</b>	<b>LOCATION(S) CONTAINING A BATH OR SHOWER</b>													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA (701.411.3.3)										✓	No		
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										N/A	No		
6.3	Shaver sockets comply with BS EN 61558-2-5 formally BS 3535 (701.512.3)										N/A	No		
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671: 2008 (701.415.2)										N/A	No		
6.5	Low Voltage (e.g.230 volts) socket outlets at least 3m from Zone 1 (701.512.3)										N/A	No		
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										✓	No		
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)										✓	No		
6.8	Suitability of current-using equipment for particular position within the location (701.55)										✓	No		
<b>7.0</b>	<b>OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied).									Number of locations	0	No		

Inspected By

Name:  Date:

Signature: 

























General condition of the installations (In terms of electrical safety), Continued. from page 1

upgrading. Cables testing ok but due to age of installation and proposed works upgrading worth consideration.

Item No	Description	Code
	(542.3; 543.1.1)	
4	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.4 Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)	C3
5	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.10 Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)	C3
6	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.16 Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.11)	C3
7	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.18 RCD(s) provided for fault protection – includes RCBOs(411.4.9; 411.5.2; 531.2)	C2
8	4 CONSUMER UNIT (S) / DISTRIBUTION BOARD(S) 4.19 RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1)	C2
9	5 FINAL CIRCUITS 5.18 Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))	C3

**Code Key**

C1 - Danger present. Risk of injury. Immediate remedial action required

C2 - Potentially dangerous - urgent remedial action required

C3 - Improvement recommended

FI - Further investigation required without delay



DB 1, 1/S, Sockets - Remarks

**Socket under radiator doesnt work**

DB 1, 2/S, Lights - Remarks

**Switch at bottom of stairs will not switch**

**Switch at female toilet wont switch off**

**Cover on light at DB missing**

DB 2, 1/S, Sockets - Remarks

**Socket loose in smaller room**

DB 2, 2/S, SPARE (Circuit Not Tested) - Remarks

**Could not identify circuit**

DB 3, 1/S, Sockets - Remarks

**RCD not tripping**

DB 4, 1/S, Sockets - Remarks

**RCD not tripping**

DB 4, 2/S, Lights - Remarks

**RCD not tripping**

DB 4, 3/S, SPARE (Circuit Not Tested) - Remarks

**Cant identify circuit 3**

DB 5, 1/S, Cooker - Remarks

**RCD not tripping**

DB 5, 2/S, Kitchen Sockets - Remarks

**RCD not tripping**

DB 5, 3/S, Sockets - Remarks

**RCD not tripping**

DB 5, 4/S, Lights - Remarks

**RCD not tripping**

**Switch at kitchen door not switching**

DB 5, 5/S, Doorbell - Remarks

**RCD not tripping**

## CONDITION REPORT GUIDANCE NOTES FOR RECIPIENTS

**This report is an important and valuable document which should be retained for future reference.**

1. The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
3. The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates residual current devices (RCD) there should be a notice at or near the device stating that it should be tested quarterly. **For safety reasons it is important that this instruction is followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially Dangerous"), the safety of those using the installation may be at risk and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.